

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. **63**

Dated: **17/02/2026**

It is certified that an inspection team headed by **Rajnish Kumar Thakur**

(Name of Officers with designation) from **Assistant Engineer, P.H. Sub. Division, Danapur**

inspected the **St. Joseph Global School, Chhitnawan, Danapur, Patna - 801503**

(Name & Address of the school) on **05.02.2026** (date of inspection) and on the basis of

Water Test Report (Attached) bearing no..... dated.....

of (PHED Lab) certified that


the **St. Joseph Global School, Chhitnawan, Danapur** (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till **6 months**

Signature with Seal: 

Name

: **Rajnish Kumar Thakur**

Designation

: **Assistant Engineer, P.H. Sub Division, Danapur**

Name & Address of the Office / Department :

To

St. Joseph Global School,

Chhitnawan, Danapur, Patna - 801503

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

475 63

17-02-2026

Government Of Bihar

Public Health Engineering Department

Water Quality Testing Report

Division Name : Patna West, Patna

Sl. No.	Block	Panchayet	Village	Habitation/ Ward no.	Location	Physico - Chemical and Bacteriological Parameters							Date of Sample Received	Date of Sample Tested	Remarks (safe or unsafe	
						pH	EC	TDS	Total Hardnes s	Ca	Mg	Cl				Alkalinit y.
1	Danapur			Chhnanwan	St. Josep h Global School	7.19	368	260	192	38	16	20	224	07.02.26	09.02.26	
Desirable Limit*						6.5- 8.5	-	500	200	75	30	250	200			
Permissible Limit* in absence of alternate source						NR	-	2000	600	200	100	1000	600			

Note: * (i) Drinking Water Specification Second Revision -IS:10500:2012., (ii) BDL means Below Detection Limit., (iii) NR means no relaxation. (iv) **

Neetu Singh
10/02/2026
Chemist

Sub Divisional Lab . Danapur
Patna West, Patna

P.H. Singh
17/02/2026
Assistant Engineer,
P.H. Sub Division , Danapur
Patna West, Patna